

GENERAL NOTE:
 ALL SITE FIXINGS
 TO STRUCTURE AND
 CONTINUOUS MASTIC
 BEAD REQUIRED TO
 ALL INTERFACES
 (BY INSTALLERS)

SOUND INSULATION

SS-600 ACOUSTIC LOUVRE
 SILL INTO MASONRY

PERFORATED INNER
 ACOUSTIC BLADE

BIRD MESH

100x50x2mm
 ANGLE
 FIXING CLEAT

MASONRY ANCHOR
 (2-PER CLEAT)
 (BY INSTALLER).


SILL FLASHING
 (BY INSTALLER)

MASTIC BEAD
 & BACKING ROD

PACKERS

620 ACOUSTIC DEPTH

20

| Rev | Description | Date |
|--|-------------|-----------------------|
|  commercial louvres & solar shading | | |
| 3/109 Ledger Road BEVERLEY SA 5009 ABN 20 143 060 360 Telephone (08) 8243 0011 Facsimile (08) 8243 0711 | | |
| Project DESIGN STAGE 1 | | |
| Title ACOUSTIC LOUVRE SILL INTO MASONRY SS - 600 | | |
| Drawn | DW | Checked |
| Date | 13/05/2011 | Scale |
| Drawing No. | DAW-008 | Revision No. REV A |

Element Control Systems
 © Copyright